



BEXAR COUNTY FIRE MARSHAL'S OFFICE

622 DOLOROSA
SAN ANTONIO, TEXAS 78207-4535
TEL: 210.335.0300 FAX: 210.335.0330



CHIRS LOPEZ
Fire Marshal

MOBILE FOOD VENDORS

Mobile food vendors conducting business within the unincorporated areas of Bexar County (outside city limits) are required to have their food trucks and/or trailers registered and permitted on an annual basis. The following constitutes a mobile food vendor:

- A registered and/or licensed vehicle
- A registered and/or licensed trailer
- Any mobile structure on wheels

Mobile food trucks and trailers shall meet, but are not limited to, the following local requirements:

1.	Registered and inspected by the Fire Marshal's Office on an annual basis. <ul style="list-style-type: none"> • Fee of \$125.00 payable to <i>Bexar County Clerk</i> is due with application
2.	Inspected by Bexar County Health Department <ul style="list-style-type: none"> • Contact Environmental Services at (210)335-6700
3.	Current State license plate tag
4.	Current inspection tag
5.	Minimum of one <u>2A10BC</u> fire extinguisher within truck or trailer <ul style="list-style-type: none"> • Must be easily accessible at all times • Must be serviced & tagged annually by a licensed company
6.	A "Class K" fire extinguisher, if a deep fryer is in use <ul style="list-style-type: none"> • Must be easily accessible at all times • Must be serviced & tagged annually by a licensed company
7.	Electrical wiring inside truck/trailer must be in conduit <ul style="list-style-type: none"> • No exposed or spliced wiring
8.	Wiring and/or cords used for outdoor lighting must be rated for outdoor use <ul style="list-style-type: none"> • No exposed or spliced wiring • Must not be subject to damage by vehicle traffic
9.	All electrical outlets, switches, and junction boxes must have cover plates
10.	Any light fixtures within truck or trailer must have their protective covers in place
11.	Propane tanks must be secured properly with a chain or strap
12.	Propane supply hoses must be stainless steel/metal
13.	"No Smoking" signs must be posted at or near propane tanks
14.	Vent Hood must be free of excessive grease build-up
15.	No flammable liquids shall be stored inside truck or trailer